



# CASE COMMENT REPORT

CASE NO. UDP-S24008

DEVELOPMENT SERVICES DEPARTMENT 700 NW 19<sup>TH</sup> AVENUE FORT LAUDERDALE, FLORIDA 33311 URBAN DESIGN AND PLANNING DIVISION 954-828-6520 www.fortlauderdale.gov



# CITY OF FORT LAUDERDALE



# **CASE INFORMATION**

CASE: UDP-S24008

MEETING DATE: March 12, 2024

**REQUEST:** Site Plan Level II Review: Additional Boat Lift

APPLICANT: Renee Biron

AGENT: Renee Biron

**PROJECT NAME**: Biron Boat Lift

**PROPERTY ADDRESS:** 1180 N. Federal Highway

**ZONING DISTRICT**: Boulevard Business (B-1)

LAND USE: Commercial

**COMMISSION DISTRICT**: 2 – Steven Glassman

**NEIGHBORHOOD ASSOCIATION:** Lake Ridge Civic Association

CASE PLANNER: Nicholas Kalargyros

# **RESUBMITTAL INFORMATION**

- Applicants must provide written responses to all DRC comments contained herein.
- Written responses must specify revisions made to the plans and indicate the sheet.
- Resubmitted plan sets must be accompanied by responses to be accepted.
- Any additional documentation must be provided at time of resubmittal.
- Resubmittals must be conducted through the City's online citizen's portal LauderBuild.
- Questions can be directed to the Case Planner assigned to the case.

DRC Comment Report: URBAN DESIGN & PLANNING

**Member:** Nicholas Kalargyros nkalargyros@fortlauderdale.gov 954-828-5193

Case Number: UDP-S24008

### **CASE COMMENTS:**

Please provide a response to the following:

- 1) The applicant is strongly encouraged to contact neighbors adjacent to, as well as condominium and neighborhood associations located within three hundred feet (300') of the development site, to advise of this proposal (a listing of officially-recognized neighborhood associations is provided on the City's website: <a href="https://www.fortlauderdale.gov/government/departments-a-h/city-manager-s-office/office-of-neighbor-support/neighborhood-associations">https://www.fortlauderdale.gov/government/departments-a-h/city-manager-s-office/office-of-neighbor-support/neighborhood-associations</a>). Provide acknowledgement and/or documentation of any public outreach.
- 2) The site is designated Water on the City's Future Land Use Map. The proposed additional boat lifts are permitted in this designation. This is not a determination on consistency with Comprehensive Plan Goals, Objectives and Policies.
- 3) The proposed boat lift extends beyond the maximum 25 feet permitted distance from the wetface of the seawall and will need review and recommendation by the Marine Advisory Board (MAB) and City Commission review and approval. A separate application and fees are required for MAB. For more information about the MAB, please contact Andrew Cuba via email at <a href="mailto:acuba@fortlauderdale.gov">acuba@fortlauderdale.gov</a> or by phone at 954-828-5236.
  - The proposed site plan requires a 30-day City Commission request for review period prior to review and recommendation by MAB.
- 4) Pursuant to State Statute 166.033(1) the application must be deemed approved, approved with conditions, or denied within 180 days of completeness determination, on or before August 3, 2024, unless a mutually agreed upon time extension is established between the City and the applicant. Please provide a statement requesting and agreeing to a waiver of these timeframes or request a specified amount of additional time to address the comments and provide sufficient time for review and approval. Failure to meet the applicable timeframe or request an extension may result in the application being denied by the City and the applicant may be required to refile a new application and fees to proceed.
- 5) Provide the technical specifications from the manufacturer (shop drawings) for the proposed boat lift.
- 6) Applicant proposes additional dockage (boarding platform), provide an approval letter from the Broward County Environmental Protection Department, contact Julie Krawczyk (954-519-1266) prior to Final Development Review Committee submittal.

### GENERAL COMMENT

- 7) An additional follow-up coordination meeting may be required to review project changes necessitated by the DRC comments. Prior to routing your plans for Final DRC sign-off, please schedule an appointment with the project planner (Nicholas Kalargyros by calling 954-828-5193) to review project revisions and/or to obtain a signature routing stamp. Please note applicant is responsible for obtaining signatures from all discipline members that had comments and may need to resolve comments through individual appointments if necessary.
- 8) Additional comments may be forthcoming at the DRC meeting. Please provide a written response to all DRC comments after comments have been received.



UDP-S24008 - Biron Boat Lift - 1180 N. Federal Hwy

